

# Operation of service Previdia Compact fire panel



**ALARM:** Notification of a fire alarm is activated in the system.  
An Alarm starts the all the signalling devices for evacuation of the premises  
Manual call point activates an Evacuation.  
When Alarm transmits a signal to the fire department.



**SILENCE:** To stop the signalling devices when the situation is under control:  
Turn the key on the control panel, press “SILENCE”.  
A yellow light is lit to indicate the alarm is silenced.  
The signalling devices will be licensed short time after.



Turn the key on the control panel, press “RESET”.  
If the yellow blocking light is lit, press SILENCE before RESET



This button will silence the control panel buzzer



A fault of any kind is present in the system. The detailing of an active fault are shown on the screen. If the indication LED is flashing, the fault has been solved and the panel can be reset.